

# Certificate



Certificate no.

CU 72092451 01

**License Holder:**

JTEKT Corporation  
1-1 Asahimachi, Kariya  
AICHI 448-8652  
JAPAN

**Manufacturing Plant:**

JTEKT Corporation  
1-1 Asahimachi, Kariya  
AICHI 448-8652  
JAPAN

**Test report no.:** USA-PS 30470676 008

**Client Reference:** Shigeo Yamamoto

**Tested to:** UL 508:1999 R8.00/07.01  
CAN/CSA C22.2 No. 0-M91  
CAN/CSA C22.2 No. 142-M1987 (R2000)  
IEC 61508-1:1998  
IEC 61508-2:2000  
see also additional page[s]

**Certified Product:** Ind. Ctl. Equip. for Safety-related Functions **License Fee - Units**

**Listing Category:** Industrial control equipment  
for Safety-Related Functions and E-Stop (per NFPA 79)

**Model Designation:** TOYOPUC-PCS,  
**Safety-Related Programmable Fieldbus Controller:**  
CPU (TAC-6089); RMT-S (TAU-6102); S-BUS (TAU-6098);  
DI001 (TAK-6090); SPM002 (TAK-6177); DI003 (TAK-6104);  
DO002 (TAK-6093); DO003 (TAK-6108); BASE8 (TAR-6149);  
BASE12 (TAR-6094); FAN2 (TAU-6208); P-FLT (TAU-6207);  
BASE5 (TAR-6148)

contd.

**Special Remarks:** Replaces Certificate CU72080532.  
**Appendix:** 1

**Licensed Test mark:**



**Signature**

**Dipl.-Ing. M. Glagla**  
**QA Certification Officer**

**Date of Issue**

(day/mo/yr)

18/12/2009

# Certificate



Certificate no.

CU 72092451 02

**License Holder:**

JTEKT Corporation  
1-1 Asahimachi, Kariya  
AICHI 448-8652  
JAPAN

**Manufacturing Plant:**

JTEKT Corporation  
1-1 Asahimachi, Kariya  
AICHI 448-8652  
JAPAN

**Test report no.:** USA-PS 30470676 008

**Client Reference:** Shigeo Yamamoto

**Tested to:** IEC 61508-3:1998  
NFPA 79:2007 ER 1  
see also previous page [s]

**Certified Product:** Ind. Ctl. Equip. for Safety-related Functions License Fee - Units

contd.

Rated Voltage: DC 24V  
Rated Power: 50W  
Circuit Class: 2 (per NEC)

Additional Standards: see above

Licensed Test mark:



Signature

Dipl.-Ing. M. Glagla  
QA Certification Officer

Date of Issue  
(day/mo/yr)

18/12/2009